

1 ENLARGED PLAN



3 ENLARGED PLAN

SYMBOL LEGEND

- FIXED CCTV CAMERA. SURFACE MOUNT TO ROOF STRUCTURE.
- POLE MOUNTED CCTV PAN TILT ZOOM CAMERA.
- V1 ELECTRICAL CONNECTIONS REQUIRED 120VAC, 1PHASE POWER FOR PAN CAMERA.
- V2 ELECTRICAL CONNECTIONS REQUIRED 120VAC, 1PHASE EMERGENCY POWER FOR 24V GATE OPERATOR.
- V3 ELECTRICAL CONNECTIONS REQUIRED 120VAC, 1PHASE EMERGENCY POWER FOR SLIDE GATE OPERATOR.
- REMOTE CONTROL AND MONITORING OF GATE OPERATOR.
- CR CONTROL AND MONITORING STATION AT SECURITY CONSOLE.
- INTERCOM PEDESTAL MOUNTED. SEE DETAIL 2/D0.08.

NOTE: ALL DETENTION LOCKING SYSTEMS WILL PROVIDE FORCES PER IBC 408.4.1 AS FOLLOWS: REMOTE RELEASE BY LOCAL DAYROOM CONTROLLER WITH CONTROL TAKE OVER REDUNDANCY AT MASTER CONTROL. FOLLOWING SYSTEMS ARE POWERED BY GENERATOR POWER. ALL LOCKS AND SLIDE DOOR DEVICES ARE POWERED WITH UPS BY OTHERS.



4 ENLARGED PLAN



5 ENLARGED PLAN



2 ENLARGED PLAN



6 ENLARGED PLAN

CLARK COUNTY DETENTION FACILITY
1000 EMERGENCY BEDS
LAS VEGAS, NEVADA

DGI of Nevada, Ltd.

1066 Executive Parkway
Suite 100
St. Louis, MO 63141

The MOLASKY GROUP OF COMPANIES
311 S. Maryland Parkway
Las Vegas, Nevada 89109

REVISIONS

24/00 SYSTEM
BEST FOR CONSTRUCTION

CURTIS A. TRUE
REGISTERED
No. 6769
10/12/07
ARCHITECT
STATE OF NEVADA

PROJECT NO. 07227.03
DATE Dec. 12, 2007
DRAWN BY DMD
CHECKED BY TP

SHEET CONTENTS

SPECIAL SYSTEMS
FIN ARCHO
SITE PLANS

SHEET

D0.6