



Department of Administrative Services Purchasing and Contracts

500 S Grand Central Pky 4th Fl • Box 551217 • Las Vegas NV 89155-1217
(702) 455-2897 • Fax (702) 386-4914

Sabra Smith Newby, Chief Administrative Officer
Adleen B. Stidhum, Purchasing Manager



CLARK COUNTY, NEVADA BID NO. 603593-15 ANNUAL REQUIREMENTS CONTRACT FOR VIDEO SURVEILLANCE (CCTV) SYSTEM

August 5, 2015

ADDENDUM NO.5

INVITATION TO BID

1. The Bid opening date of August 6, 2015 has been changed to August 7, 2015 at 3:00:00 p.m.

EXHIBITS

2. **Delete** instruction provided per Addendum No.3, Item No.4 (Exhibit G DJJS Campus, Security System Upgrade: **Delete** page TY5.00 and replace with the revised page TY5.00, attached hereto) in its entirety as the wrong exhibit and location within the instructions was referenced.
3. Exhibit E – Spring Mountain Youth Camp Surveillance System Installation: **delete** page TY5.00 and **replace** with the revised page TY5.00, attached hereto.
4. Exhibit F - Spring Mountain Youth Camp Residential; Security Surveillance System Installation: **delete** page TY5.00 and **replace** with the revised page TY5.00, attached hereto.
5. Exhibit G - DJJS Campus; Security Surveillance System Upgrade: **delete** page TY6.02 and **replace** with the revised page TY6.02, attached hereto.

Except as modified herein all other bid specifications, terms, and special provision shall remain the same.

Should you have any questions, I can be reached via email at Chetanc@ClarkCountyNV.Gov.

ISSUED BY:

CHETAN CHAMPANERI
Purchasing Analyst

Attachment: Exhibit E - Spring Mountain Youth Camp Surveillance System Installation: Page TY5.00
Exhibit F - Spring Mountain Youth Camp Residential; Security Surveillance System Installation:
Page TY5.00
Revised Exhibit G – DJJS Campus; Security Surveillance System Upgrade: Page TY6.02


Cc: Chuck James, Real Property Management
John Rodriquez, Real Property Management
Carolyn Banks, DJJS
James Scorson, DJJS
Jack Martin, DJJS
Brian Connolly, Real Property Management
Fernando Martinez, Real Property Management
Michael Whelihan, DJJS
Amanda Carnahan, DJJS

NOTICE:

1. SURVEILLANCE INTEGRATOR SHALL PROVIDE (2) RACK POWER DISTRIBUTION UNITS (PDU) WITH (L21-20P) PLUG. PDU TO BE MOUNTED ON BACKSIDE OF RACK.

NOTES:

- 1 ELECTRICAL CONTRACTOR SHALL PROVIDE RACK AND (2) 120VOLT 20AMP CIRCUIT FROM THE NEAREST 120VOLT 20AMP SPARE CIRCUIT BREAKER IN AN EXISTING PANEL. MOUNT (2) 20AMP RECEPTACLE WITHIN THE RACK. REFER TO SHEET TY2.05 FOR EXISTING ELECTRICAL PANELS LOCATION.



SURVEILLANCE RACK LOCATED IN BUILDING D CENTRAL PLANT

SURVEILLANCE RACK ELEVATION

NO SCALE

1
TY5.00

| REVISIONS | BY | DATE |
|-----------|----|----------|
| 1 | JS | 07-29-15 |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |

D:\RPM-Standard\Disk\TRANSFER
FILECOVER.dwg

Coda Architecture, LLC
817 South Main Street
Las Vegas, Nevada 89101
P 702.336.7594

CLARK COUNTY
DEPARTMENT OF REAL PROPERTY MANAGEMENT
ACQUISITION, DESIGN, & CONSTRUCTION DIVISION
500 S. GRAND CENTRAL PARKWAY
Las Vegas, Nevada
(702) 455-4917



RP.C9D14041, CCGC-SPRING MOUNTAIN YOUTH
CAMP SURVEILLANCE SYSTEM INSTALLATION
CAMPUS SECURITY INSTALLATION
SURVEILLANCE RACK ELEVATION

TY5.00



JBA Las Vegas
5155 W Patrick Ln
Las Vegas, NV 89118
P 702.362.9200


#14.0111

NOTICE:

1. REFER TO SHEET TY2.01 FOR HEAD-END EQUIPMENT LOCATION.
2. CONTRACTOR SHALL COORDINATE VIEWING LOCATIONS TO COMPLY WITH THE PRISON RAPE ELIMINATION ACT (PREA).

NOTES:

- ① COORDINATION OF WORKSTATION LOCATION SHALL BE BETWEEN CONTRACTOR AND OWNER'S REPRESENTATIVE.
- ② CONTRACTOR SHALL SUPPLY AND INSTALL ALL PATCH CORDS.




SURVEILLANCE SINGLE LINE DIAGRAM DETAIL

NO SCALE

1
TY5.00

NOTES:

- ① CONTRACTOR TO PROVIDE MIDDLE ATLANTIC EWR 16-22 WALL MOUNTED RACK.
- ② CONTRACTOR SHALL PROVIDE (1) 120VOLT 20AMP CIRCUIT FROM THE NEAREST 120VOLT 20AMP SPARE CIRCUIT BREAKER IN AN EXISTING PANEL BOARD WITH 1/2"-2#12 AND 1#12 GROUND TO A 20AMP RECEPTACLE WITHIN THE RACK.



TYPICAL RACK ELEVATION

NO SCALE

2
TY5.00

| REVISIONS | BY | DATE |
|-----------|----|------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

D:\RPM-Standard\Disk\TRANSFER
FILECOVER.dwg

Coda Architecture, LLC
817 South Main Street
Las Vegas, Nevada 89101
P 702.336.7594

CLARK COUNTY
DEPARTMENT OF REAL PROPERTY MANAGEMENT
ACQUISITION, DESIGN, & CONSTRUCTION DIVISION
500 S. GRAND CENTRAL PARKWAY
Las Vegas, Nevada
(702) 455-4917



RP.C0914043, CCGC SPRING MOUNTAIN YOUTH
CAMP RESIDENTIAL FACILITY SECURITY
SURVEILLANCE SYSTEM INSTALLATION
CAMPUS SECURITY INSTALLATION
SINGLE LINE DIAGRAM


TY5.00

NOTICE:

1. SURVEILLANCE INTEGRATOR SHALL PROVIDE (2) RACK POWER DISTRIBUTION UNITS (PDU) WITH (L21-20P) PLUG. PDU TO BE MOUNTED ON BACKSIDE OF RACK.

NOTES:

- 1 ELECTRICAL CONTRACTOR SHALL PROVIDE RACK AND (2) 120VOLT 20AMP CIRCUIT FROM THE NEAREST 120VOLT 20AMP SPARE CIRCUIT BREAKER IN AN EXISTING PANEL. MOUNT (2) 20AMP RECEPTACLE WITHIN THE RACK. REFER TO SHEET TY2.05 FOR EXISTING ELECTRICAL PANELS LOCATION.



SURVEILLANCE RACK ELEVATION

NO SCALE

1
TY6.02

| REVISIONS | BY | DATE |
|-----------|----|------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Coda
6853B W. Charleston Blvd.
Las Vegas, Nevada 89117
P 702.795.2285

CLARK COUNTY
DEPARTMENT OF REAL PROPERTY MANAGEMENT
ACQUISITION, DESIGN, & CONSTRUCTION DIVISION
500 S. GRAND CENTRAL PARKWAY
Las Vegas, Nevada
(702) 455-4917



RP.D0914037, CCGC DJJS CAMPUS:
SECURITY SURVEILLANCE
SYSTEM UPGRADES
DESIGN DETAILS

TY6.02

P:\14\110\Drawings\BAA\TY6.02\TY6.02.dwg, 8/20/15 8:43:57 AM, Dimen:Comden, Baa.dwg, PLOT, pcd, ARCH, C:\Users\jba\AppData\Local\Temp\11