



Department of Administrative Services

Purchasing and Contracts

500 S Grand Central Pky 4th Fl • Box 551217 • Las Vegas NV 89155-1217
(702) 455-2897 • Fax (702) 386-4914

Sabra Smith Newby, Chief Administrative Officer
Adleen B. Stidhum, Purchasing Manager



CLARK COUNTY, NEVADA
BID NO. 604083-16
LAS VEGAS BOULEVARD FROM ST. ROSE PARKWAY TO SILVERADO RANCH
BOULEVARD

July 29, 2016

ADDENDUM NO. 2

INVITATION TO BID

1. The bid opening date of Wednesday, August 24, 2016 at 2:15:00 **remains unchanged.**

REQUESTS FOR INFORMATION AND ANSWERS

2. Refer to the attached "Question & Answer Sheet" attached to this Addendum 2.

Except as modified herein and in Addendum 1, all other bid specifications, terms, conditions and special provisions shall remain the same.

ISSUED BY:

THOMAS E. BOLDT, C.P.M.
Senior Purchasing Analyst

Attachment(s): Question & Answer Sheet

Cc: Spring Dineen, Public Works
Joe Yatson, Public Works
Mike Mamer, Public Works
Cindy Beauchamp, Public Works

Bid 604083-16 Question and Answer Sheet

- Q1. We, Polymer Pipe Technology / PolymerCrete (also known as Interpipe), would like to ask to be listed by name as an approved vendor / supplier of the polymer concrete manholes specified under ASTM C478 outlined in the project specification for the upcoming Las Vegas Boulevard project Bid No 604083-16.
- A1. In order for a product to be named on the CCWRD Approved Supplier List it must first be reviewed and approved by the CCWRD committee for the Approved Materials list. This process takes months and we do not have the time in this projects bid period. You can call (702)668-8160 if you would like to apply to be on the list for future jobs.
- Another possibility is if the contractor really wants to use your product they can submit a deviation to CCWRD after the bid period and CCWRD Assistant General Manager over Collection System Services and the County's design engineer will review and determine if the product is acceptable. However, this process does not put your product on the CCWRD Approved Materials List.
- Q2. Olson Precast Company is requesting that concrete sewer manholes including concrete bases with corrosion protection be allowed on this project.
- A2. The CCWRD will allow the contractor to use pre-cast concrete manholes with corrosion protection for new construction on the Las Vegas Blvd Project bid # 604083-16. An addendum will be issued revising the plans and specifications.
- Q3a. We would like to ask the following pre-bid RFI questions in regards to the Las Vegas Blvd. project that is currently bidding:
- CLSM as approved by the Engineer." Please provide the allowable trench width for the RCB installation should CLSM be utilized.
- A3a. This detail is being revised and will be part of an addendum.
- Q3b. Will the County provide the CAD files for the project for takeoff purposes?
- A3b. Yes I can provide CAD files, they will be sent in a separate email from my engineer.
- Q4. We are looking for cross sections for this project. Will those be coming in an addendum?
- A4. We do have cross sections for this project. I will have my engineer GCW provide them.
- Q5. We are trying to find out what we need to do to take some Pot Test Holes on this project. Is there a permit needed? O K let me know I would appreciate it.
- A5. Before you can do any pot holing in the ROW you will need to obtain an encroachment permit from the Clark County Public Works Dept. located at 500 South Grand Central Parkway, Las Vegas. Information on obtaining an encroachment permit is located on our website, follow the link:
- <http://www.clarkcountynv.gov/public-works/construction-Mgmt/Pages/EncroachmentPermits.aspx>
- Q6. Bid item 627.01 Permanent Signs (Ground Mounted)(Metal Supports), are these signs going to be installed per NDOT Standards or Clark County Standards? Or a combination of both? And if both types of installations are going to be utilized from what station to what station is NDOT ROW and from what station to what station is Clark County ROW? Can you please clarify as there is a substantial cost difference between the two entities methods for installation.
- A6. None of the sign work for this project falls within NDOT ROW. All signs will be installed per Clark County standards.