



# DEPARTMENT OF BUILDING & FIRE PREVENTION BUREAU

4701 W. RUSSELL RD, LAS VEGAS, NV 89118

## FIRE INSPECTION TIPS FOR NEW BUSINESSES

Below is a list of the most common violations found during a fire inspection for a new business:

### 1. EXIT SIGNS—

Make sure that all illuminated exit signs are working properly.

### 2. EMERGENCY LIGHTS -

Make sure that if your exit sign has emergency lights on the side or top that they light up when pressing the TEST button. If they do not come on when you press the TEST button you will probably need to replace the battery inside the exit sign.

### 3. EXITS -

All exits should be unblocked and there should be a clear path to the exit door.

### 4. FIRE EXTINGUISHERS -

Provide fire extinguishers that are currently serviced by a Nevada licensed extinguisher company. The Fire Extinguisher must be mounted no higher than 5 feet off the ground and near an exit.

### 5. EXTENSION CORDS -

Remove all extension cords. UL Listed surge protectors are allowed if they are plugged directly into an electrical outlet.

### 6. ELECTRICAL PANEL—

The electrical panel in your location must be unblocked and have a 3 foot clear space around the panel.

### 7. COMPRESSED GAS CYLINDERS—

All compressed gas cylinders must be secured to a wall with a chain or other reliable material.