



Clark County Department of Building & Fire Prevention

Building Division – Inspection Services

Field Inspection Guideline

SUBJECT:	Performance Test Certification	FIG-M-005
Effective Date:	November 16, 1999	Revised: March 16, 2015
		Approved By: BAT
Code Chapter:	2012 UMC Amendment Section 511.2.4	Page 1 of 1

Interpretation:

The above amendment section cites the requirements for performance tests on exhaust equipment used in conjunction with commercial heat-processing equipment. This amendment of the Clark County Mechanical Code, Section 511.2.4, provides the installer the option of performing the test using an approved third party testing agency or (at the discretion of the Building Official) using a Building Department representative that shall witness the test by an approved third party testing agency.

Field Application Prior to Inspection Scheduling:

When performance testing is verified by a third party agency (QAA), a completed copy of the report shall be submitted to the inspector for review. Upon completion of the review and subsequent approval, a copy of the performance report shall be forwarded to the Department Records Division for inclusion with the permanent records. This shall include third party testing of Type I hoods, duct detectors and dampers. Performance testing conducted in the presence of a building department representative shall not require the submittal of a performance report.

Revision History:

Reference #	Title	Effective Date	Revised	Reviewed
FIG-M-005	Review and Certification/Performance Test	November 16, 1999		May 31, 2013
FIG-M-005	Review and Certification/Performance Test			May 22, 2014
FIG-M-005	Review and Certification/Performance Test		March 16, 2015	