



# Clark County Department of Building & Fire Prevention

## Building Division – Inspection Services

### Field Inspection Guideline

<b>SUBJECT:</b>	Exhaust Systems	<b>FIG-M-011</b>
<b>Effective Date:</b>	April 13, 1993	<b>Revised:</b> March 10, 2015
		<b>Approved By:</b> BAT
<b>Code Chapter:</b>	2012 UMC Section 508.0 Section 517.0	<b>Page 1 of 1</b>

**Interpretation:**

**508.0:** Pizza oven venting of combustion products under a Type II Hood shall be an acceptable method for venting the oven under the following conditions:

**Field Application:**

The venting of pizza ovens into a Type II Hood shall be an acceptable method for venting gas combustion products provided the oven manufacturer permits this as an acceptable installation.

**Section 517.0:** Wood burning pizza ovens shall be accordance with Section 517.0 of the UMC shall be under a type I hood and be provided a dedicated hood.

**Revision History:**

Reference #	Title	Effective Date	Revised	Reviewed
FIG-E-011	Pizza Oven Venting	April 13, 1993		May 31, 2013
FIG-E-011	Pizza Oven Venting			June 03, 2014
FIG-E-011	Pizza Oven Venting		March 10, 2015	