



# Clark County Department of Building & Fire Prevention

## Building Division – Inspection Services

### Field Inspection Guideline

<b>SUBJECT:</b>	<b>Non-Metallic Flex Duct Installations</b>	<b>FIG-M-013</b>
<b>Effective Date:</b>	<b>May 25, 1993</b>	<b>Revised: March 10, 2015</b>
		<b>Approved By: BAT</b>
<b>Code Chapter:</b>	<b>Installation Manual Air Diffuser Council Guidelines</b>	<b>Page 1 of 1</b>

**Interpretation:**

The Air Diffuser Council sets the guidelines for the installation of non-metallic flex duct.

**Field Application:**

Non-metallic Flex ducts shall not be collapsed or restricted when installed within construction. The Air Diffuser Council defines collapsed as “any reduction in the external or internal cross-sectional area of the duct in excess of 20 percent.

**Revision History:**

Reference #	Title	Effective Date	Revised	Reviewed
FIG-M-013	Non-Metallic Flex Duct Installations	May 25, 1993		May 31, 2013
FIG-M-013	Non-Metallic Flex Duct Installations			June 04, 2014
FIG-M-013	Non-Metallic Flex Duct Installations			March 10, 2015