Clark County Department of Building & Fire Prevention
Building Division – Inspection Services
Field Inspection Guideline

SUBJECT:	**UL Listed Duct Tape for Rigid and Flexible Duct**		**FIG-M-016**
Effective Date:	***April 1998***	***Revised: March 10, 2015***	***Approved By: BAT***
Code Chapter:	**2012 UMC Section 602.4**		**Page 1 of 1**

Interpretation:

Section 608.1 of the Mechanical Code, states the requirement for tapes.

Field Application:

Closure systems for flexible air ducts shall be in accordance with U.L. 181B labeled tape. Tape used to seal joints on rigid duct shall be labeled with U.L. 181A. The face of these tapes shall bear the following information:

1. Manufacturers Name
2. U.L. Listing number
3. Listing for Class I duct systems.

Revision History:

Reference #	Title	Effective Date	Revised	Reviewed
FIG-M-016	UL Listed Duct Tape for Rigid and Flexible Duct	April 1998		May 31, 2013
FIG-M-016	UL Listed Duct Tape for Rigid and Flexible Duct			June 04, 2014
FIG-M-016	UL Listed Duct Tape for Rigid and Flexible Duct		March 10, 2015	