



# Clark County Department of Building & Fire Prevention

## Building Division – Inspection Services

### Field Inspection Guideline

<b>SUBJECT:</b> <b>Wall Covering Adjacent to Type I Hoods</b>	<b>FIG-M-019</b>
<i>Effective Date:</i> <b>April 13, 1992</b>	<i>Revised:</i> <b>March 10, 2015</b>
<i>Approved By:</i> <b>BAT</b>	
<i>Code Chapter:</i> <b>2012 UMC Section 507.2</b>	<b>Page 1 of 1</b>

**Interpretation:**      Section 507.2 of the Mechanical Code, states the clearance requirements for Type I Hoods from combustible construction.

**Field Application:**    Grease duct hoods, grease removal devices, exhaust fans, and ducts shall have a clearance of not less than 18 inches to combustible materials but maybe reduced to 3 inches to limited combustible materials and 0 inches to non-combustible materials.

**Revision History:**

Reference #	Title	Effective Date	Revised	Reviewed
FIG-M-019	Wall Covering Adjacent to Type I Hoods	April 13, 1993		May 31, 2013
FIG-M-019	Wall Covering Adjacent to Type I Hoods			June 04, 2014
FIG-M-019	Wall Covering Adjacent to Type I Hoods		March 10, 2015	