



Clark County Department of Building & Fire Prevention

Building Division – Inspection Services

Field Inspection Guideline

SUBJECT:	SWG Btu/h Content in One Cu Ft of Natural Gas = 1,000 Btu's	FIG-P-002		
Effective Date:	May 17, 2007	Revised: Updated	Approved By:	GJF
Code Chapter:	Figure 12-2 2006 UPC		Page 1 of 1	

Field Application:

By the **Memo of Understanding** from **Southwest Gas Corporation** received February 8, 2007 the Btu/h content in one cubic foot of gas will remain at 1,000. This figure will be the common denominator that this jurisdiction will use to figure the cubic foot per hour of gas demand.

Example:

Natural Gas Fired Forced Air Unit Heater = 80,000 Btu Input rating
 $80,000 \div 1,000 = 80$ cubic foot per hour

This letter (attached) supersedes any prior communication from Southwest Gas Corporation on this matter. Please destroy any older letters, and memos of understanding from Southwest Gas Corporation on this subject.