



Clark County Department of Building & Fire Prevention

Building Division – Inspection Services

Field Inspection Guideline

SUBJECT:	Two-Way Cleanout Installation	FIG-P-009		
Effective Date:	February 24, 2000	Revised: April 10, 2007	Approved By:	GJF
Code Chapter:	2006 UPC Section 719.4			Page 1 of 1

Interpretation:

Section 719.4 requires each clean out fitting to be installed so that it opens to allow cleaning in the direction of flow of soil and waste piping.

Field Application:

The use of combination fittings (full size) set in opposing directions. The upstream combination fitting installed in the direction of drainage flow and the downstream combination fittings installed against the direction of flow is an acceptable method of providing access to drainage systems for the purpose of cleaning the system. The standpipe (vertical portion) shall be extended (full size) from each combination fitting to grade. This method can be used in with any of the approved materials listed in Section 701.1.