



Clark County Department of Building & Fire Prevention

Building Division - Inspection Services

Field Inspection Guideline

SUBJECT:	Piping Installed Above Grade or Structure	FIG-P-011	
Effective Date:	September 24, 2007	Revised: New	Approved By: GJF
Code Chapter:	1211.1.6 Amendments	Page 1 of 1	

Interpretation:

2006 UPC code Section 1211.1.6 has been deleted and amended to read:

Section 1211.1.6 No gas piping shall be installed in or on the ground under any building or structure unless installed in a gastight conduit, and all exposed gas piping shall be kept at least **six (6) inches above grade or structure**. The term "**building or structure**" shall include: porches and steps, covered or uncovered, breezeways, roofed porte-cocheres, roofed patios, carports, covered walks, covered driveways, and similar structures or appurtenances. All gas piping under a slab shall be capable of being removed and replaced.

Field Application:

The flat stacking of 3 nominal 2 x 4's, shall be allowed to meet the above requirement of maintaining six (6) inches above grade or structure. The material used shall be of red wood, cedar, wolmanized, or any decay resistant lumber.
Spacing shall be in accordance with Table 3-2 or Table 12-3.