



Clark County Department of Building & Fire Prevention

Building Division – Inspection Services

Field Inspection Guideline

SUBJECT:	Handicap Vs. Water conservation Lavatory Faucets	FIG-P-025		
Effective Date:	November 16, 1995	Revised: April 11, 2007	Approved By:	GJF
Code Chapter:	2006 UPC Section 402.0			Page 1 of 1

Interpretation:

The UPC lists the requirements for commercial lavatory faucets. An exception to that is made for lavatories that are required to meet the A.N.S.I. “Accessible” standard. This exception shall be applied in the following manner:

Field Application:

All commercial lavatory faucets shall comply with the Water Conservation Section (402.4) of the code. They shall deliver a maximum of .25 gallons of water per use.

Exception:

Lavatory faucets complying with the Accessibility Standard may be substituted for faucets that would be required to meet the Water Conservation Ordinance. Those faucets will be permitted on a one-to-one ratio. One accessible faucet will be permitted for each accessible water closet.