



Clark County Department of Building & Fire Prevention

Building Division – Inspection Services

Field Inspection Guideline

SUBJECT:	Termination of T&P Drain Lines	FIG-P-028		
Effective Date:	March 18, 1993	Revised: April 11, 2007	Approved By:	GJF
Code Chapter:	2006 UPC Amendments			Page 1 of 1

Interpretation:

The Plumbing Code Amendments states the requirements for proper termination of temperature and pressure relief drains. These drains are to terminate to the exterior of the building or to “other approved locations”. Other approved locations shall be defined as follows:

Field Application:

Temperature and pressure relief drains located inside the building shall terminate by means of a drain to one of the following other approved locations:

1. To a floor sink
2. To a mop sink
3. To a washing machine standpipe through an air break
4. To a funnel drain

Examples of locations that are not approved for termination of T&P drain lines are floor drains and garage floors.