



Department of Development Services

Building Division

4701 W. Russell Rd • Las Vegas NV 89118
(702) 455 8335

Ronald L. Lynn, Director/Building Official

September 24, 2009

To: Pool and Spa Industry of Southern Nevada
From: Department of Development Services, Building Division
Re: ROUGH AND FINAL GAS LINE INSPECTIONS GAS TEST AND TAG

Please find this information as a **30 day calendar notice** to the above industry of corrective enforcement by this department. Enforcement shall begin no sooner than **October 26, 2009**.

The 2006 Uniform Plumbing Code Sections: **1204.3.1 Rough Inspection 1204.3.2 Final Inspection and 1205.1 Certificate of Inspection** outline the provisions of inspecting permitted installations of gas piping and the issuance of gas tags or electronic approvals.

Rough Inspection: “This inspection shall be made after all gas piping authorized by the permit has been installed and before any such piping has been covered or concealed”...

Final Inspection: “This inspection shall be made after all piping authorized by the permit has been installed and all portions thereof that are to be covered or concealed are so concealed”... This includes backfilling of excavations.

Certificate of Inspection: “If, upon final piping inspection, the installation is found to comply with the provisions of this code, a certificate of inspection may be issued by the AHJ”... As of the above enforcement date this jurisdiction will no longer issue or conduct gas test and tag inspections while trenches or excavations are open. This is being done to reduce occurrences of gas piping damage.

Please direct all questions concerning this document to Dennis Daniels, Building Inspection Plumbing Specialist @ 455-8339 or Mike Giordano, Building Inspection Mechanical Specialist @ 455-8388.

BOARD OF COUNTY COMMISSIONERS

CHIP MAXFIELD, Chair • MYRNA WILLIAMS Vice-Chairman
YVONNE ATKINSON GATES • MARK A JAMES • RORY REID • BRUCE L WOODBURY • MARY J. KINCAID-CHAUNCEY
THOM REILLY, County Manager