



CLARK COUNTY DEPARTMENT OF BUILDING

Fire Prevention Bureau

4701 West Russell Road, Las Vegas, NV 89118
(702) 455-7316 FAX (702) 455-7347

OTC-006

Effective Date: 09/30/2013





Revision Date:

**TITLE: OVER THE COUNTER (OTC) PLAN REVIEW
LPG for Group R-3 Occupancies**

SCOPE: Clark County Fire Prevention Bureau requirements for the submittal of LPG for Group R-3 occupancies. This permit type applies only to installations in residential occupancies and does not include LP-gas installations for businesses or retail sales. Note: All initial installations require a permit, but no renewals are required for residential LPG tanks.

The following is required:

- Provide a site plan including your name, address, and contact phone number.
- Provide the location of the LPG tank.
- Provide the size of the LPG tank in water gallons.
- Provide the distances to structures, property lines, and public ways
- Fire Plans Checker/FPE will verify compliance with Table 3804.3 Location of LP-gas Containers.
- Fire Plans Checker/FPE will enter the total gallons in the IFV log in Naviline (aggregate if there is more than one tank).

Prepared By	Concurred By	Approved By
		
Joe Dodd Fire Plans Checker	Girard Page Senior Deputy Fire Chief	Ron Lynn Building Official
Reviewed By	Reviewed By	
		
Kurt Gottschalk Deputy Fire Marshal	Donna Starks Deputy Fire Marshal	