



# CLARK COUNTY DEPARTMENT OF BUILDING

## Fire Prevention Bureau

4701 West Russell Road, Las Vegas, NV 89118  
(702) 455-7316 FAX (702) 455-7347

**OTC-007**

Effective Date: 09/30/2013

Revision Date:

**TITLE: OVER THE COUNTER (OTC) PLAN REVIEW  
Mobile Hot Work - Temporary**

**SCOPE:** Clark County Fire Prevention Bureau requirements for the submittal of Mobile Hot Work. This permit type applies only to hot work operations performed in the field at various locations and does not include performing hot work at a designated location at a specific address, such as, a permanent shop or place of business.

The following is required:

- Provide a letter including your business name, address, contact phone number, and a detailed narrative describing the type of hot work operations performed in the field (welding, cutting, grinding, etc.)
- Include the type of hot work equipment to be used.
- Location, type and volume (in cubic feet) of compressed gas cylinders, if used.
- Provide and maintain a signed copy of the Hot Work Operations/Fire Watch Procedures and Safety Sign-off Sheet (pgs. 4-6 of the Hot Works Guideline).
- Provide a fire watch in accordance with the Clark County Fire Code.

Prepared By	Concurred By	Approved By
Joe Dodd Fire Plans Checker	Girard Page Senior Deputy Fire Chief	Ron Lynn Building Official
Reviewed By	Reviewed By	
Kurt Gottschalk Deputy Fire Marshal	Donna Starkes Deputy Fire Marshal	