



Clark County Building Department

4701 West Russell Road • Las Vegas NV 89118

(702) 455-3000 • Fax (702) 221-0630

Division:	Plans Exam, Engineering & Inspection	Code Interpretation	BD-CI-039
Subject:	SILL ANCHORAGE	Effective Date:	09/03/2011
Code:	2024 IBC Section 2308.7.1.1, 2308.7.1.2, and 2021 ANSI/AWC SDPWS Section 4.3.6.4.3	Revised Date:	01/06/2026

A. CODE REQUIREMENT

Sections 2308.7.1.1 and 2308.7.1.2 require that braced wall line sill plates be anchored with anchor bolts with 0.229 inch by 3 inch by 3 inch steel plate washers between the foundation sill plate and the nut or approved anchor straps in Seismic Design Category D and E.

B. INTERPRETATION

Engineered designs shall comply with Section 2305 and the reference standard. Projects which are detailed in accordance with the prescriptive provision in section 2308 do not require any calculations. Steel plate washers (0.229 inch by 3 inch by 3 inch) shall be required at all braced wall lines regardless of the Seismic Design Category, unless exempted by the ANSI/AWC SDPWS section 4.3.6.4.3. Exterior walls and interior bearing walls in Seismic Design Category D, E, or F that are not designed as shear walls are required to have anchor bolts with steel plate washers unless a design which provides code intended anchorage is specified. A registered design professional's specification of anchor bolts with standard cut washers at these locations will be deemed as an adequate design.

C. RATIONALE

This is a clarification of the code requirement to ensure consistent enforcement. The requirement for sill plates, anchor bolts and washers is specified in IBC Sections, 2308.7.1 and 2308.9.3. The conventional construction provisions are intended when calculations are not being provided. Compliance to the conventional construction provisions is, therefore, necessary for anchorage of walls not subject to design protocol. Anchorage is required in accordance with Section 2308.7.1 which indicates "a properly sized nut and washer shall be tightened on each bolt to the plate." It is silent on the necessary washer size for other walls not part of a braced wall line. Section 2308.1 and 2308.4 allow for methods other than conventional provisions outlined in Section 2308 as long as a satisfactory design is submitted showing compliance with other provisions of the IBC.

A registered design professional's seal on the drawings and calculations is deemed adequate to meet this requirement for Section 2308.4. No specific calculation for the plate washers will be required. Exterior walls and interior bearing walls in Seismic Design Category A, B, or C that are not designed as shear walls are required to have anchor bolts with standard cut washers. Please note that interior non-load bearing partitions of conventional light-frame construction are not subject to the limitations of Section 2308. These walls are understood to only separate interior space and do not resist gravity or lateral loads attributed from other portions of the structure. A design may be provided for these walls and sill anchorage based on loads specified in IBC Section 1607.16. The sill anchorage may be provided by anchor bolts and standard cut washers or some proprietary product subject to design based on attached materials and any limitations of use.

Prepared by: Building Division

Date Prepared: 01/06/2026

Revision History:

Title	Revision/Approved Date	Effective Date
Sill Anchorage	BD-CI-039	09/03/2011
Sill Anchorage	BD-CI-039	11/05/2012
Sill Anchorage	BD-CI-039	05/01/2013
Sill Anchorage	BD-CI-039	10/30/2013
Sill Anchorage	BD-CI-039	03/02/2015
Sill Anchorage	BD-CI-039	01/06/2026

Reviewed by:

Jake Mizrahi

Jake Mizrahi

Engineering Manager

Terry Kozlowski

Terry Kozlowski

Manager of Plans Exam.

Lisa Mohit

Lisa Mohit

Senior Management Analyst

Matthew Brewer

Matthew Brewer

Manager of Inspections

Zach Gharibian

Zach Gharibian

ACET Manager

James Oleniczak

James Oleniczak

Senior Management Analyst

Theresa Atimalala

Theresa Atimalala

Senior Management Analyst

Werner Hellmer

Werner Hellmer, P.E., CBO

Deputy Director

Scott Telford

Scott Telford, P.E., CBO

Deputy Director

Approved by:

James Gerren

James Gerren, P.E. C.B.O

Director & Building Official

Sill Anchorage