

801.3.4 FLOOR SINK INSTALLATION DETAIL

Clark County
Building Department
4701 W Russell Rd
Las Vegas, NV 89118
(702) 455-3000

Boulder City
Building Department
401 California Avenue
Boulder City, NV 89005
(702) 293-9282

Henderson
Building & Fire Safety Department
240 S. Water Street
Henderson, NV 89015
(702) 267-3650

Las Vegas
Building & Safety
495 S. Main Street
Las Vegas, NV 89101
(702) 229-6251

2024 UPC 801.3.4 AMENDED

FLOOD LEVEL RIM OF FLOOR SINKS SHALL BE INSTALLED WITH THE FINISHED FLOOR, SEALED WITH NO GAPS, AND SHALL BE ACCESSIBLE FOR CLEANING

