



CLARK COUNTY FIRE DEPARTMENT - FIRE PREVENTION BUREAU

4701 W Russell Rd, Las Vegas, NV 89118 • (702) 455-7316

Website: [Fire Department \(clarkcountynv.gov\)](http://Fire Department (clarkcountynv.gov))

Email: FPPCQ@clarkcountynv.gov

Permit Submittal Guideline

PROPRIETARY SELF MONITORING

This guide is to assist in the permitting process for proprietary self-monitoring. A permit is required for the operation of proprietary self-monitoring per section 105.5.62 of CCFC.

APPLICABLE CODES:

The following codes and standard apply to this permit:

- *National Fire Alarm and Signaling Code*, NFPA 72, 2022 edition
- *International Fire Code*, (IFC) 2024 edition
- *Clark County Fire Code Amendments*, (CCFC) 2024 edition

Proprietary self-monitoring shall be implemented in accordance with Appendix P of CCFC.

SUBMITTAL REQUIREMENTS:

These submittal requirements are not all inclusive, nor are they a limit to the extent of the information, etc., which may be necessary to properly evaluate the submitted plans and documents. Not all items may apply to your project.

1. **PLANS / REPORT:** To be designed to include all details of Appendix P of the CCFC and saved to a PDF file.
2. **MATERIAL DATA:** Provide manufacturer's specification sheets for all components.
3. **SUPPORTING DOCUMENTS:** Provide documents that support the design/application. These would include a copy of an approved Fire Protection Report (FPR)/Alternative Material and Method Report (AMMR), a copy of the originally approved plans/report, and existing component specification sheets that affect system performance.
4. **Plans to be REVIEWED AND SIGNED:** By the property owner or owner's representative.
5. **TESTING & INSPECTION:** The testing & inspection shall be in accordance with CCFC Appendix P.