



# Clark County Building and Fire Prevention Field Inspection Division **FIELD INSPECTION GUIDELINE**

<b>Division:</b>	<b>Inspections</b>	<b>Policy &amp; Procedure:</b>	<b>FIG-P-003</b>
<b>Subject:</b>	<b>Combustion Air in Garage</b>	<b>Effective Date:</b>	<b>05/04/1998</b>
<b>Code:</b>	<b>2018 Uniform Plumbing Code, Section 506.2.1</b>	<b>Revised Date:</b>	<b>10/01/2020</b>
<b>Proposed:</b>	<b>Matthew Brewer</b>	<b>Approved:</b>	<b>Sam Palmer</b>

**Interpretation:**

Air provided through openings other than specific combustions air openings may be used, including such openings as those around vehicle access garage doors. Use the “standard method” outlined in Section 506.2.1.

**Field Application:**

Take the sum of all the gas fired appliances input ratings that are located in the garage, and the available room volume using the formula of 50 cubic feet per 1000 Btu’s.