NCR - 0 to 15 days NCR - 16 to 44 days NCR - 45 days and up Work covered or loaded ROC Issued



Clark County Building Department

4701 W. Russell Road • Las Vegas, NV 89118 (702) 455-3000 • Fax (702) 221-0630

Agency Logo

Jerome A. Stueve, P.E., Director Samuel D. Palmer, P.E., Assistant Director • James Gerren, P.E., Assistant Director

			VIA	Samuel D. Palmer, P.E., Assistant Director • James	Gerren, P.E., As	ssistant Director		Start-Up Form Date:	02/02/21
Project Name:				Naaltsoos Sání Casino &	Naaltsoos Sání Casino & Resort				04/25/25 BDIA19-00012
Form 887	Inspection Agency Name:			Gur Consulting & Inpection	Gur Consulting & Inpections Inc.				BD18-12345
Work Covered or Loaded?	SEOR Approved?	CCBD Approved?	NCR number	NCR Scope - Gridline / Elevation Location	Date of Issuance	ROC Date	No. Days from NCR Issuance	RFI number / Revisio	n No. / Comments
			NCR-CR-01	Wrong longitudinal rebar size at shear No.8 instead of No. 9, located at C.25 from 3 to 6.5, second level mezzanine	15/12/21		1227	Non approved deta	il onsite RFI 0032
			NCR-CC-02	Not approved mix design for shear wall pour, located at C.25 from 3 to 6.5, second level mezzanine	20/11/21		1252	GC mentioned that CC r missing PI	
V			NCR-SS-01	A325 bolts for shear connection at A.5/C were left outside bolt container during two days prior to installation	20/09/21		1313		
		V	NCR-CC-03	Not approved mix design for concrete deck, existing NCR on connection beneath (See NCR-SS-010	15/09/21		1318		
		√	NCR-M-01	Concesion builing NEC, Not approved masonry inspector fabrication prisms on site	10/04/21	15/12/21	1476	Agency mentioned that req to C	
			NCR-M-02	Not approved plans for consecion building at NEC	25/06/21		1400	GC mentioned that they a approval, non appro	-
							0		
							0		
							0		
							0		
							0		
							0		
							0		
							0		
							0		



			0	
			0	
			0	