

2024 UPC 1210.1.6 GAS PIPING INSTALLED UNDERGROUND BENEATH BUILDINGS AMENDED

Clark County
Building Department
4701 W Russell Rd
Las Vegas, NV 89118
(702) 455-3000

Boulder City
Building Department
401 California Avenue
Boulder City, NV 89005
(702) 293-9282

Henderson
Building & Fire Safety Department
240 S. Water Street
Henderson, NV 89015
(702) 267-3650

Las Vegas
Building & Safety
495 S. Main Street
Las Vegas, NV 89101
(702) 229-6251

2024 UPC 1210.1.6 AMENDED

CONDUIT WITH BOTH ENDS TERMINATING INDOORS. WHERE THE CONDUIT ORIGINATES AND TERMINATES WITHIN THE SAME BUILDING, THE CONDUIT SHALL ORIGINATE AND TERMINATE IN AN ACCESSIBLE PORTION OF THE BUILDING AND SHALL NOT BE SEALED.

NOTE:

THIS DETAIL IS FOR USE WITH RIGID GAS PIPING INSTALLED BELOW SLAB.

